

Professional Testing Laboratory Inc.

TEST REPORT

DATE: 03-04-2022	Page 1 of 1	TEST NUMBER:	0284833
CLIENT	Egetaepper a/s		

	ASTM E662 Smoke Density (Non-Flaming) Standard Test Method for
TEST METHOD CONDUCTED	Specific Optical Density of Smoke Generated by Solid Materials also
	referenced as NFPA 258



	DESCRIPTION OF TEST SAMPLE
IDENTIFICATION	Colortec 80/20 1500 LT

GENERAL PRINCIPLE

This procedure is designed to measure the specific optical density of smoke generated by the test specimen within a closed chamber. Each specimen is exposed to an electrically heated radiant-energy source positioned to provide a constant irradiance level of 2.5 watts/square cm on the specimen surface. Measurements are recorded through a photometric system employing a vertical beam of light and a photo detector positioned to detect the attenuation of light transmittance caused by smoke accumulation within the chamber. The light transmittance measurements are used to calculate specific optical density, a quantitative value which can be factored to estimate the smoke potential of materials. Two burning conditions can be simulated by the test apparatus. The radiant heating in the absence of ignition is referred to as the Non-Flaming Mode. A flaming combustion in the presence of supporting radiation constitutes the Flaming Mode.

	CONDIT	IONS (1997) ve nytřišeběkázky sklyževntejásace	distributed for the first and the second of the first second of the seco
PREDRYING OF TEST SAMPLE	24 Hours at 140° F		
CONDITIONING OF TEST SAMPLE	24 Hours at 70° F and 50% Relative Humidity		
TESTING CONDITION	As Received		
FURNACE VOLTAGE	118 V	IRRADIANCE	2.5 watts/sq cm
CHAMBER TEMPERATURE	95° F	CHAMBER PRESSURE	3" H ₂ O
TEST MODE	Non-Flaming		

AVERAGE MAXIMUM DENSITY CORRECTED (Dmc) NON-FLAMIN		NON-FLAMING	79	
AVERAGE SPECIFIC OPTICAL DENSITY AT 4.0 MINUTES			33	
	Specimen 1	Specimen 2	Specimen 3	
Maximum Density (Dm)	78.0	82.0	80.0	
Time to Dm (minutes)	20.0	19.0	20.0	
Clear Beam (Dc)	0.0	1.0	1.0	
Corr. Max Density (Dmc)	78.0	81.0	79.0	
Density at 1.5 minutes	9.0	9.0	8.0	
Density at 4.0 minutes	33.0	34.0	31.0	
Time to 90% Dm (minutes)	16.0	14.0	15.5	
Specimen Weight (grams)	11.5	11.5	11.5	

^{*} This sample PASSES the requirements of 450 or less.

APPROVED BY:

This facility is accr

This facility is accredited by the National Voluntary Laboratory Accreditation Program for the specific scope of accreditation under Lab Code 100297. This accreditation does not constitute an endorsement, certification, or approval by NIST or any agency of the United States Government for the producttested. This report is provided for the exclusive use of the client to whom it is addressed. It may be used in its entirety to gain product acceptance from duly constituted authorities. This report applies only to those samples testedand is not necessarily indicative of apparently identical or similar products. This report, or the name of Professional Testing Laboratory, Inc. shall not be used under any circumstance in advertising to the general public.



714 Glenwood Place

Dalton, GA 30721

706-226-3283

Fax: 706-226-6787

protest@optilink.us

TEST REPORT

DATE: 03-04-2022	Page 1 of 1	TEST NUMBER: 0284833
CLIENT	Egetaepper a/s	

	ASTM E662 Smoke Density (Flaming) Standard Test Method for Specific
TEST METHOD CONDUCTED	Optical Density of Smoke Generated by Solid Materials also referenced
	as NFPA 258



DESCRIPTION OF TEST SAMPLE
IDENTIFICATION Colortec 80/20 1500 LT

GENERAL PRINCIPLE

This procedure is designed to measure the specific optical density of smoke generated by the test specimen within a closed chamber. Each specimen is exposed to an electrically heated radiant-energy source positioned to provide a constant irradiance level of 2.5 watts/square cm on the specimen surface. Measurements are recorded through a photometric system employing a vertical beam of light and a photo detector positioned to detect the attenuation of light transmittance caused by smoke accumulation within the chamber. The light transmittance measurements are used to calculate specific optical density, a quantitative value which can be factored to estimate the smoke potential of materials. Two burning conditions can be simulated by the test apparatus. The radiant heating in the absence of ignition is referred to as the Non-Flaming Mode. A flaming combustion in the presence of supporting radiation constitutes the Flaming Mode.

	CONDITIO	NS	
PREDRYING OF TEST SAMPLE	24 Hours at 140° F		
CONDITIONING OF TEST SAMPLE	24 Hours at 70° F and 50% Relative Humidity		
TESTING CONDITION	As Received		
FURNACE VOLTAGE	118 V	IRRADIANCE	2.5 watts/sq cm
CHAMBER TEMPERATURE	95° F	CHAMBER PRESSURE	3" H₂O
TEST MODE	Flaming		

AVERAGE MAXIMUM DENSITY CORRECTED (Dmc) FLAMING AVERAGE SPECIFIC OPTICAL DENSITY AT 4.0 MINUTES			252
			46
	Specimen 1	Specimen 2	Specimen 3
Maximum Density (Dm)	197.0	299.0	266.0
Time to Dm (minutes)	10.0	10.0	10.5
Clear Beam (Dc)	3.0	2.0	2.0
Corr. Max Density (Dmc)	194.0	297.0	264.0
Density at 1.5 minutes	3.0	10.0	5.0
Density at 4.0 minutes	34.0	57.0	46.0
Time to 90% Dm (minutes)	8.0	7.5	8.5
Specimen Weight (grams)	11.4	11.5	11.6

^{*} This sample PASSES the requirements of 450 or less.

APPROVED BY:

This facility is accredited by the National Voluntary Laboratory Accreditation Program for the specific scope of accreditation under Lab Code 100297. This accreditation does not constitute an endorsement, certification, or approval by NIST or any egency of the United States Government for the producttested. This report is provided for the exclusive use of the client to whom it is addressed. It may be used in its entirety to gain product acceptance from duly constituted authorities. This report applies only to those samples testedand is not necessarily indicative of apparently identical or similar products. This report, or the name of Professional Testing Laboratory, Inc. shall not be used under any circumstance in advertising to the general public.



Fax: 706-226-6787 protest@optilink.us