

**TEXTILNÍ ZKUŠEBNÍ ÚSTAV, s.p.**  
(TEXTILE TESTING INSTITUTE)

**Notified body No. 1021**

Cejl 480/12, Zábřovice, 602 00 Brno, Czech Republic



issues

## CERTIFICATE OF CONSTANCY OF PERFORMANCE

**No. 1021 - CPR – 012-1/16**

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

### **Textile floor coverings: Product group 1B - WO/PA-WT**

Material:	80% wool/ 20% polyamide
Primary backing:	polyester
Secondary backing:	woven secondary backing
Technology:	tufted – cut pile

Products placed on the market under the name or trade mark of:

Manufacturer: **Ege Carpets A/S**  
Industrivej Nord 25, DK-7400 Herning, Denmark  
ID: CVR 38454218

Manufacture location: 1) Ege Carpets A/S - Industrivej Nord 25, DK-7400 Herning, Denmark  
2) Ege Carpets A/S - Industrivej 3, DK-6510 Gram, Denmark

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard:

**EN 14041:2004/ AC:2006 Resilient, textile and laminate floor coverings – Essential characteristics**

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.


Products fulfil the essential characteristic **of reaction to fire: Class B<sub>fl</sub> – s1**

The present certificate was issued on the basis of the protocol No. 1021/16/033 (22.02.2016), No. 1021/18/071 (13.04.2018) and No 1021/20/115 from 16.04.2020 issued by NB 1021 TZÚ Brno. Detailed description of product group is stated in Annex No. 1 of the certificate.

This certificate was first issued on February 22, 2016 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



Brno, 16.04.2020



RNDr. Pavel Malčík  
Managing Director

**SCOPE:**

**Group 1B - WO/PA-WT (80% Wool/ 20% Polyamide / Woven secondary backing)**

<b>Group 1.1 (WO/PA-WT)</b>		Tufted	Cut Pile
<b>Class B<sub>fl</sub> – s1</b>			
<i>Total weight</i>	2 900 – 3 100 g.m <sup>-2</sup>	<i>Total thickness</i>	8,5 – 9 mm
<i>Pile weight</i>	1 400 – 1 600 g.m <sup>-2</sup>	<i>Pile thickness</i>	6 – 6,5 mm
<i>Classification report</i>	VN710 165508.3 (03.03.2020)	<i>Classification</i>	EN 13501-1 + A1
<i>Products in group</i>	<b>Highline 80/20 1400 WT      Highline 80/20 1600 WT</b>		

<i>Field of application</i>	Horizontal laid floor coverings in form of <b>rolls</b> . The carpet is to be mounted on a substrate of Euroclass A1 <sub>fl</sub> or A2 <sub>fl</sub> with a density of at least 1350 kg.m <sup>-3</sup> . It is declared for installation with a polyacrylat - copolymer dispersion adhesive (Ege 90RH/ UZIN UZ 57 ) or similar.
-----------------------------	--

**TEST REPORTS and DOCUMENTATION:**

<i>Product</i>	<i>Test report</i>	<i>Date</i>	<i>Accredited laboratory</i>	<i>Product documentation</i>
<b>Highline 80/20 1400 WT</b>	PF13144b	16.4.2010	DBI	04.02.2016
<b>Highline 80/20 1600 WT</b>	PFA10023	14.6.2011	DBI	

